






## Nominated Safety Switches (04/2017)

### Nominated RCD Requirements







- Type: RCCB
- RC Type: AC
- Current: 40A
- Residual Current: 30mA
- Poles: 2
- Trip Time: < 40ms
- Standard: AS/NZS 61008.1:2015 or IEC 61008-1 Ed. 3.2

ABB	FH202 AC-40/0,03	
Clipsal	RCD240/30	
legrand	TX <sup>3</sup> 4115 10	
NHP	MOD6 RCCB 2 4030	



### Nominated Double Pole RCBOs (RCD/MCBs)






- Type: RCBO
- RC Type: AC
- Current: 10A / 16A
- Residual Current: 30mA
- Poles: 2
- Trip Time: < 40ms
- Short-Circuit Capacity: 6kA
- Standard: AS/NZS 61009.1:2015 or IEC 61009-1 Ed. 3.2

ABB	DS201BS C10 AC30	
ABB	DS201BS C16 AC30	
Clipsal	RCBM210/30	
Clipsal	RCBM216/30	
legrand	DX <sup>3</sup> 4110 00	
legrand	DX <sup>3</sup> 4110 02	



### Nominated Single Pole RCBOs (RCD/MCBs)

- Type: RCBO
- RC Type: AC
- Current: 10A / 16A
- Residual Current: 30mA
- Poles: 1
- Trip Time: < 40ms
- Short-Circuit Capacity: 6kA
- Standard: AS/NZS 61009.1:2015 or IEC 61009-1 Ed. 3.2

ABB	DSN201 C10 AC30	
ABB	DSN201 C16 AC30	
NHP	M6 RCBD 1030C	
NHP	M6 RCBD 1630C	
legrand	DX <sup>3</sup> 6027 82	
legrand	DX <sup>3</sup> 6027 83	